Franklin Fueling Systems

Sump Inspection Register

Date of Inspection or Test	Results of Inspection or Test	Signature of Inspector or Tester

Required Monthly And/Or Annual Inspection: Containment sumps located on the property at which the FFS products are installed must be visually inspected for liquid monthly. Sump sensors, if installed, must be tested annually. Any leaks must be corrected at the time they are found.
Recommended Monthly Inspection: Verify sump lids are tight and sealed. Inspect sumps for dirt, debris, liquid or any physical cracks or holes that would allow leakage. Check for evidence of staining or new staining. Verify penetration boots are in good condition and the pipe entry into the sump is positioned properly (near perpendicular entry). Verify sump liquid sensors are positioned correctly if installed. Verify the piping and other equipment in the sump are in good condition.

Record any faults on this Sump Inspection Register and have the fault(s) corrected at the time found.

Additional copies of this form can be downloaded from the FFS website www.franklinfueling.com

End user proprietary inspection check register log formats or any form to record these inspections is acceptable.

Franklin Fueling System GmbH • Rudolf-Diesel-Strasse 20 • 54516 Wittlich, GERMANY
Tel: +49-6571-105-380 • Fax: +49-6571-105-510

© FFS 2011 408001011 rev 2