



# Coaxial Hoses

---

## Installation Instructions

Tapered threads should be covered with non hardening UL approved, gasoline-resistant, sealing compound. Straight threads must not use sealing compound. O-rings on hoses must be lubricated with light oil before assembly to HEALY accessories. Use wrenches on fitting flats only and torque to 35-70 foot-pounds.

## Healy Coaxial Hose Notice

HEALY hoses contain various combinations of tapered (pipe) threads and straight threaded fittings. Be sure you have correctly matched threads before assembly. Do not attempt to use non-HEALY accessories on HEALY Vapor Recovery Systems.

