



Franklin Fueling Systems

Date: March 24, 2007

Bulletin No: B0307-05

To: Healy Distributors

From: Leon Schuster

Subject: Dispensing Systems Hanging Hardware

It has been brought to our attention that there is some confusion in the field regarding the use of Vapor Systems Technologies (VST) Healy-style coaxial hoses and breakaways in California. In an effort to educate Healy distribution on the misuse of VST hoses in Healy sites, please carefully review the following.

At this time, VST Healy-style hoses and breakaways can NOT be used on underground storage tank (UST) sites that follow California Air Resources Board (CARB) Phase II Enhanced Vapor Recovery (EVR) Executive Orders VR-201 and VR-202. The Franklin Fueling Systems (FFS) / Healy Phase II EVR equipment listed in Exhibit #1 of the VR-201 and VR-202 Executive Orders does NOT allow for any alternative suppliers of the coaxial hoses or breakaways. The use of Healy-style hoses and breakaways supplied by VST on sites following Executive Orders VR-201 and VR-202 will result in a Notice of Violation (NOV) and penalties for use of non-CARB approved EVR equipment.

Although not recommended by FFS, the use of VST Healy-style products at existing sites, operating under a non-EVR certified Executive Order (EO), is allowed per CARB certification letters 94-28 and 97-5 as follows:

- VST Healy-style hoses and VST-H-BSK breakaway may be used on existing UST sites that are operating under EO #G-70-191-AA, under EO #G-70-186, or under EO #G-70-187

Please contact Franklin Fueling Systems Technical Service if you have any questions regarding the equipment outlined above or any other concerns.

Thank you,

Leon Schuster
Dispensing Systems Product Manager



Marketing Bulletin