Franklin Fueling Systems

APT Sump Inspection Register

Date of Inspection or Test	Results of Inspection or Test	Signature of Inspector or Tester

Required Monthly And/Or Annual Inspection: Containment sumps located on the property at which the APT products are installed must be visually inspected for liquid monthly. Sump sensors, if installed, must be tested annually. Any leaks must be corrected at the time they are found.
Recommended Monthly Inspection: Verify sump lids are tight and sealed. Inspect sumps for dirt, debris, liquid or any physical cracks or holes that would allow leakage. Check for evidence of staining or new staining. Verify penetration boots are in good condition and the pipe entry into the sump is positioned properly (near perpendicular entry). Verify sump liquid sensors are positioned correctly if installed. Verify the piping and other equipment in the sump are in good condition.

Record any faults on this Sump Inspection Register and have the fault(s) corrected at the time found.

Additional copies of this form can be downloaded from the APT website www.flexpipe.com

End user propriatary inspection check register log formats or any form to record these inspections is acceptable.

APT • 3760 Marsh Road • Madison, WI 53718 USA
Tel: +1 608 838 8786 • 800 225 9787 • Fax: +1 608 838 6433 • www.flexpipe.com

FFS-0015 11/04